

Dedicated Capital Development Project Request

2023 General Session Authorization for Fiscal Year 2024

Weber State University Engineering Technology Building Renovation – Phase II

New space0Remodeled space34,866Total Project space34,866Demolished space0

Project Cost	\$8,298,958
Anticipated Dedicated Funds	\$8,298,958
Other Funds	0

Describe source and amount of other funds; attach letter(s) of commitment from donors that cite timing and amount of any donations

Institutional reserves, State Capital Improvement, and Energy Savings Reserves were used to cover the entire the first phase of this renovation. Dedicated development funding is needed to fund this critical second phase.

□ Letter(s) of commitment attached

Threshold requirements for capital projects: refer to R741-4 for instructions; ensure criteria are fully addressed

1. Cost Effective and Efficient Use of Resources

The renovation will preserve the structure and exterior of the facility as well as the basic floor plan layout. This will save several million dollars over the cost of a new facility. It will also remove several million from our deffer maintenance program. The new systems currently planned for the space were also evaluated using the total cost of ownership. The systems will reduce the operating and maintenance cost and help the institution become carbon neutral.

2. Consistent with Institutional Role, Mission, and Master Plan

The Utah State Board of Regents has approved four new degrees that will be housed within the college: i. Masters Degree – Computer Science ii. Masters Degree – Electrical Engineering iii. Bachelor of Science – Mechanical Engineeringiv. Bachelor of Science – Manufacturing

Systems EngineeringScience, Technology, Engineering and Math (STEM) programs fuel the economic engine for much of northern Utah. With Hill AFB and its highly technical missions such as supporting the F-35 and ICBM programs, as well as other aerospace and scientifically related industrial giants like ATK, Boeing and other technical based firms increasing their presence in the area, the demand for engineers and engineering technicians can simply not be satisfied. This need forhighly trained technically qualified employees is particularly acute in electrical and computer engineering and in the technicians who support the engineers. Currently, Utah companies have to import people skilled in these areas because the entire higher education system in the state cannot support the demand. According to Department of Workforce Services analysis, the college satisfies the most critical industry needs of software engineering, electrical engineering, and mechanical engineering and technology. This project will help redress that deficiency and allow Weber State University to educate highly skilled people who can fill highly compensated positions in these technical areas. Keeping these jobs in Utah helps the economy, improves the tax base, raises the overall standard of living, and improves Utah's competitive position in the world. The newly added Electrical Engineering Program has already produced 120 graduates. 115 of those graduates are currently employed as EE's; 109 of them in Utah:i. 49 Employed at HAFBii. 12 Employed at BAE Systemsiii. 11 Employed at Northrop Grummaniv. 8 Employed at L-3

3. Fulfillment of a Critical Institutional Need

Converting our critical academic buildings into modern, carbon neutral ready, highly effective and efficient buildings is a core strategic goal of the university. Engineering Technology is one of the oldest facilities that has not seen a major renovation since it was constructed 45 years ago. This project meet two critical needs of the institution. First, it updates antiquated spaces for new and modern programs, bringing critical programs into the 21st century. Second, the building will be converted to a carbon neutral ready mechanical and electrical systems and connect to new ground source geothermal condenser loops. EAST is one of the largest colleges at Weber State University, both in terms of students enrolled and with declared majors, and in terms of the amount of building space required to support their programs. The college is laboratory intensive and is severely overcrowded in their existing laboratory spaces. There is no room remaining for adding equipment or faculty and staff. Enrollment in the electrical and computer engineering programs is growing rapidly, reflecting the high demand for these skills and the higher compensation that can be expected. Overall, declared majors in EAST have grown from 1809 FTE in 2007 to 2479 FTE in 2017. Computer Science has grown from 203 FTE in 2007 to 1176 FTE in 2017. The electrical engineering program, which was only started in 2010, had already grown to 82 FTE by 2017. Growth in all of these programs has been accelerating each year. Between 2014 and 2016 the college experienced the greatest growth of graduates by both amount and percentage of any engineering college in the state.

FY2024 Capital Development Project Request and Needs Statement

State agencies complete pages 1-10 (blue headings). Higher Education institutions complete entire document. Please keep answers brief.

1 - GENERAL PROJECT INFORMA	TION	
Request Type:	State Funded (Not Higher Ed) Non-state Funded Non-state Funded with O&M Request	Land Bank Dedicated State Funded (Higher Ed ONLY) Non-dedicated State Funded (Higher Ed ONLY)
Agency/Institution:		
Project Name:		
Agency/Institution Priority:		
2 - PROJECT SCOPE		
New Space Constructed (GSF)	
Remodeled Space (GSF)		
Total Project Space (Gross Square	Feet)	
Space to be Demolished	(GSF)	
Types of Space (describe the type	s and amounts of space proposed to meet the progra	immatic requirements)

3 - CAPITAL FUNDING

Preliminary Cost Estimate:					
Previous State Funding:					
(Funding previously provided for the	e project such as planning, land	purchase, e	tc.)		
Other Sources of Funding:			Is the	e Funding in-hand?	
(Other sources of funding such as d debt. If debt is proposed for the pro					
FY2024 Requested Funding:			Debt	Repayment Source	
Other buildings of similar size and f	unction:				
Name	Location	Ft ²	Year Built	Construction Cost	Cost per Ft ²



Capital Development Project Capital Budget Estimate (CBE)

		_			
	ET Phase 2 MEP up				
Project Type:	Mechanical Upgrade				Duint Dute
Agency/Institution:	Weber State Univers	sity (W	SU)		Print Date
Project Manager:	Tim Parkinson		Droiget	Location: Weber C	9/8/22
Delivery Method:	CMGC - Developme	nt	Cost	Jounty	
Cost Summary	\$/SF		\$ Amount		Notes
Facility Cost	\$183.27/SF	\$	6,389,746		
Additional Construction Cost	\$0.00/SF	\$	-		
Site Cost	\$0.00/SF	\$	-		
High Performance Building	\$1.83/SF	\$	63,897		
Total Construction Cost	\$185.10/SF	\$	6,453,644		
	¢/or		^ A		
Soft Costs:	\$/SF		\$ Amount		Notes
Hazardous Materials		\$	537,381		
Pre-Design/Planning		\$	-		
Design		\$	428,522		
Property Acquisition		\$	-		
Furnishings & Equipment		\$	149,079		
Utility Fee Cost		\$	-		
Information Technology:		\$	100,031		
Utah Art (1% of Construction Budget)		\$	-		
Testing & Inspection		\$	79,745		
Contingency	6.7%	\$	432,394	0.0% New @ 0%	100.0% Remodel @ 6.7%
Moving/Occupancy		\$	51,629		
Builder's Risk Insurance (0.15% of Construction Budget)		\$	9,680		
Legal Services (0.05% of Construction Budget)		\$	3,227		
DFCM Management		\$	-		
User Fees		\$	-		
Commissioning		\$	39,939		
Other Costs		\$	13,686		
Total Soft Costs	\$52.93/SF	\$	1,845,314		
		•	0.000.050		
Total Project Cost	\$238.02/SF	\$	8,298,958		
Previous State Funding		\$	-		
Other Funding Sources (Identify in note)		\$	_		
		Ψ	-		
REQUEST FOR STATE FUNDING		\$	8,298,957.77		
Project Information					
			Base \$/SF Cost Da	te - (Date Escalatio	on Begins): 09/01/2022
			Estimated Final Bid	Date (Date Escala	tion Ends): 04/01/2023
			Estimated	Substantial Compl	etion Date: 12/01/2023
OFFICIAL UTAH DFCM CBE FORM V2.0 Last Revision: 07-27-2022				Date La	st Modified 08/31/2022
				5 4.0 Eu	

- ONGOING OPERATING BUDGET FUNDING									
Existing State-funded O&M									
Increase in State-funded O&M New Total State-funded O&M									
1. If applicable, describe all alternate p	proposed sources of O&M	funding (fees, tuition, usage charg	jes, etc.).						

2. Is the requestor seeking ongoing state funding such as O&M and future capital improvement funding? If so, please justify.

3. Other than the state requirement to comply with the DFCM high performance building standard, describe any other strategies that you plan to employ in the facility that will make its operation more efficient.

New Program Costs

4. Describe the <u>new or expanded programs and services</u> that will result if the project is funded and provide a brief description of the additional program costs, required FTEs, and anticipated funding sources below. This should include any operating budget increases required, other than O&M, in order to operate the programs that will be housed in the requested facility. If this request will make that existing state space available for alternate uses, the above estimate should also include the estimated cost of new or expanded programs and services that will be housed in the vacated space.

New FTEs Required for O&M Programs	
------------------------------------	--

O&M

Programs



CALCULATION OF O&M FUNDING FOR FY 2024 STATE-FUNDED PROJECTS

Institution: Weber State University

Project Name: Engineering Technology Renovation, Phase I & II

GSF of Project	Sq. Ft.	Rate Per Sq. Ft.*	Total Amount
New Space to be Added			
Type of Space			
Classroom/Office		\$ 8.33	\$-
Libraries/Student Centers		\$ 7.72	\$-
Service/Shops		\$ 6.13	\$-
Labs		\$ 12.75	\$-
Physical Education		\$ 7.70	\$ -
Subtotal - New Space	-	#DIV/0!	\$-
pace to be Remodeled			
Type of Space			
Classroom/Office	47,022	\$ 9.25	\$ 434,954
Libraries/Student Centers		\$ 8.58	\$ -
Service/Shops	1,919	\$ 6.81	\$ 13,068
Labs	25,925	\$ 14.16	\$ 367,098
Physical Education		\$ 8.55	\$ -
Subtotal - Remodeled Space	74,866	10.89	\$ 815,120
OTAL GSF of Project	74,866	\$ 10.89	\$ 815,120
ess Current O&M for Space Remodeled/Deleted Where Applicable**	74,866	\$ 6.35	
let Funding Request	,500		\$ 339,721

Explanation/Description:

This project request is request updated O&M funding for the entire Engineering Technology Building while the project funding request is only asking for the second phase of the construction dollars. The first phase was completed with state capital improvement dollars and institutional funding.

INSTRUCTIONS: Completion of this form is required for all state-funded projects to address questions raised by the Legislature and the O&M audit conducted by the Office of the Legislative Auditor General.

* Authorized Building Board Rates for FY 2023

**

The rate to be used for deduction of the amount applicable to remodeled/deleted space is the FY 2020 calculated actual average cost per square foot reported on Budget Form S-2 of the FY 2021 Budget Request documents.

Existing Space (square feet) Currently Occupied

1. Is the existing facility owned or leased and why is it not able to meet your needs?

2. Describe the future use of the existing facility. Include functions to be served, costs of remodeling or expansions as well as the amount of deferred maintenance and code compliance that will need to take place in the existing facility to enable it for continued use. Additionally, describe how you intend to fund it.

6 - PROJECT EXECUTIVE SUMMARY

Use this section to provide a detailed justification of why the project is needed. Please address the following questions:

1. Describe the purpose for and scope of the project in detail, including all programs and services to be offered in the proposed facility.



2. Summarize specific numbers regarding the anticipated users of the building and square footage. How many years after the competion of the building would the building be at max space utilization capacity? The space utilization plan should account for 10 years of growth within the facility (not the campus as a whole). Once constructed, how many years until it reaches full utilization?

3. Has this request been submitted in previous years? If so, describe any and all changes that have been made to this request since previously being submitted.



4. Describe the various populations or constituencies served and how they will benefit. Estimate any increases in program capacity that will result if this request is funded (e.g. number of FTE students taught, prisoners housed, court cases handled, etc.).

5. Summarize your decision-making process that has led to this project request (e.g., construction of a new facility versus remodeling an existing building or a combination of build new and remodel existing). Discuss economic, functional, and programmatic considerations involved in your proposal.



Explain the degree of urgency for the project and your options and strategies should this facility not be funded, both in the 6. interim and in the long term.



7 - FEASIBIILTY / PLANNING

Submit feasibility study (as outlined below) as an attachment to this document. The feasibility study **MUST** be prepared by a third party. Below, please include page numbers where corresponding information can be found within the feasibility study.

Feasibility Study Requirements:

- 1. Include a table of contents within the feasibility study that includes the below sections and their associated page numbers.
- 2. Describe the need for the proposed building and the appropriateness of its proposed scope and size.
- 3. Detailed scope of the project to included:
 - a. Space list outlining in detail the proposed square footage by space type such as office, classroom, conference rooms, auditorium / large meeting rooms, kitchen, laboratory (research or teaching), circulation, warehouse, shop lab, or other
 - b. Adjacency diagrams
 - c. Proposed floor plans
 - d. Proposed building elevations
 - e. Site plan options
- 4. Provide the ratio of assignable and net square feet to gross square feet.
- 5. Provide a detailed list including the justification for any unique elements or features considered to be out of the ordinary.
- 6. Provide an assessment of the potential to re-use existing or expand existing facilities to meet this need.
- 7. Provide justification for replacement of the existing facilities (if applicable) including what will be done with the existing facility such as sale, repurpose for another need, or demolition.
- 8. Provide justification for a new facility (if applicable).
- 9. Provide a space utilization study of existing and proposed space. Include the efficiency of the new space as compared to the existing space (include 5 10 year growth projections).
- 10. Identify expected building capacity percentage for the following intervals along with corresponding projected FTEs and student attendance (online students and faculty are not included):
 - a. Time of completion
 - b. Three years after completion
 - c. Five years after completion
 - d. Ten years after completion
- 11. Explain how this facility and its functions correspond with your agency or institution's Strategic Plan and campus Master Plan. Indicate when your Strategic Plan and Master Plan were last updated.
- 12. Summarize the primary priorities or growth at your agency or institution and describe how the proposed facility will serve those needs.
- 13. Where applicable, describe the potential positive and/or adverse economic and community impacts of the project
- 14. Describe any special transportation considerations for this facility including parking, transit, and pedestrian requirements
- 15. Describe your efforts to work with the surrounding communities should this facility be approved; including impacts to traffic, pedestrian safety, security, noise, excessive night time lighting, etc.
- 16. Describe the extent that you have evaluated facility siting, including alternative sites where applicable, to include:
 - a. Identification of location, size, and characteristics of the site, and estimated costs of any required environmental remediation
 - b. If the site is not owned by the State, address the availability and cost of purchasing the site and the results of any appraisals that have been performed. Agencies should work with DFCM's real estate staff in addressing potential purchases.
 - c. Provide a geotechnical report with a minimum of three borings in the proposed building site location that identify the soil classification for the building type unless waived by the DFCM director.
 - d. Explain any special soils preparation requirements or seismic conditions that could increase site and structural costs beyond those considered standard for your area.

Page Number

- 17. Describe the availability and capacity of utility services including IT for the proposed facility. Specify whether the utility services will be provided by municipal, private, or local campus centralized services.
- 18. Show how the FF&E budget was arrived at. Provide the logic behind it. If applicable, identify any furnishings or equipment that will be re-used and moved from the current facility to the new location.

8 - FIVE-YEAR PLAN

Please list below the anticipated State-funded Capital Development projects planned for your agency/institution over the next five years. Include a short description/justification of each project and the approximate cost of the project.

Project #1 Name	Approx. Cost
Funding Source	
Description	
Project #2 Name	Approx. Cost
Funding Source	
Description	
Project #3 Name	Approx. Cost
Funding Source	
Description	
Project #4 Name	Approx. Cost
Funding Source	
Description	
Project #5 Name	Approx. Cost
Funding Source	
Description	



9 - STATE SYSTEM OF HIGHER EDUCATION ADDITIONAL STATUTORY REQUIRED INFORMATION

As required by Title 63A-5-104 (2) (d) that an institution described in section 53B-1-102 that submits a request for a capital development project address whether and how, as a result of the project, the institution will:

1. Offer courses or other resources that will help meet the demand for jobs, training, and employment in the current market and the projected market for the next three, five, and ten years;

2. Help meet commitments made by the Governor's Office of Planning and Budget, including relating to training and incentives;



10 - SPACE UTILIZATION EFFORTS

The programming document shall include all of the minimum requirements of the Feasibility Study.

This section demonstrates compliance with the Board of Higher Education approved space utilization standards (Include the classroom and laboratory for now and then any future requirements for office and common area spaces).

1. Provide projected enrollment and/or employee growth specific to the requested building as well as for the institution as a whole (i.e. if the request is for a science building, provide enrollment growth for students in the science fields using the building as well as FTE growth in general for the institution). What is the estimated time frame for the building to reach full utilization?

11 - LAND BANK ACQUISITION REQUESTS

Requests for purchase of land from funds to be appropriated by the State Legislature for future use by an agency or institution will be evaluated based upon approved programmatic planning and facilities master plan requirements of the institutions.

General Considerations

Provide detail for the following considerations that will be taken into account in evaluation of these requests:

1. Provide the location and description of the property including any existing permanent structures.



2. Provide current availability of the land and "time sensitivity" of the window of opportunity for its purchase.

3. Provide the intended use of the land and its relative importance in the context of the agency or institution's role and mission assignment and strategic plan for the future.

4. Where applicable, provide the suitability of the property for the intended use (ingress/egress, proximity of utilities, percentage of buildable area, geo-technical, etc.)

5. Provide reasonableness of the cost as determined by an appraisal or other reasonable estimate of the value of the land.



6. Provide the condition of the land, including the potential liability of the institution pertaining to clearing the property, potential existence of hazardous waste, greenhouse gas emissions, etc.

7. If applicable, provide the condition and potential use of existing structures and describe what actions and incurred costs would be necessary to utilize existing structures.

12 - TECHNICAL COLLEGE STATUTORY REQUIREMENTS

State statute specifies that the State Building Board must determine that the requirements of UCA 53B-2a-112 have been met before it may consider a funding request from the Board of Higher Education pertaining to new capital facilities and land purchases. Please describe how this project has met the requirements outlined in UCA 53B-2a-112.



13 - PHOTOGRAPHS AND MAPS

Any photographs, other graphics justifying the project, and/or maps showing where the facility will be located should be attached to the end of this document and submitted electronically. These should help explain the project and justify why it should be funded.

14 - SCORING ANALYSIS FOR BOARD OF HIGHER EDUCATION CRITERIA

Please provide justification to aid the Board of Higher Education in applying Capital Development Priority Guidelines. See USHE policy R743 4.4 step 4 for detail requirements. This section only applies to state-funded project requests (dedicated or non-dedicated).

1. Cost-effectiveness and efficient use of resources

2. Consistent with institutional role, mission, and master plan





14 - SCORING ANALYSIS FOR BOARD OF HIGHER EDUCATION CRITERIA

Fulfillment of a critical institutional facility need 3.





Engineering Technology Building Renovation









WSU Engineering Technology Building Renovation Feasibility & Space Planning Report April, 2021







INDEX

- Vision & General Scope of Work
- Programming & Space Planning
- Building Plans New & Comparison
- Architectural Narrative
- Structural Narrative
- Mechanical & Plumbing Narrative
- Electrical Narrative
- Cost Estimate
- Appendix Electrical Drawings
- Appendix WSU Owner Project Requirements





VISION

WSU's College of Engineering, Applied Science and Technology (EAST) is undergoing a physical transformation. Along with the design and construction of two new buildings, the Engineering Technology Building (ET) will be renovated to replace aged building systems and to reorganize space left vacant as the new buildings are occupied. The work is expected to improve the energy efficiency of the building by replacing the old and inefficient HVAC and lighting systems. Select interior and exterior architectural elements will also be replaced to enhance energy efficiency efforts. The combined work is expected to extend the building's service life by decades, creating a reinvigorated and valuable asset for the College and University.

SCOPE OF WORK

General

The renovation includes the complete replacement of HVAC systems, significant upgrades to electrical power distribution, limited envelope upgrades, and moderate interior renovation. Except for a few minor modifications, and the seismic restraint of new equipment, no structural work is included. Site work is also not generally anticipated.

Phasing

Two phases of construction are planned to reduce the project's impact on academic operations during the fall and spring semesters, and to allow for different funding options.

The building has two distinct mechanical rooms. The north mechanical room generally feeds both floors of the north side of the building and contains a tie-in to the campus-wide steam system. The south mechanical room services the south side of the building. The north-south division of systems, and the location of the steam system tie-in, dictate which areas are phased together and how the work is sequenced.

The first phase of work will address the south half of the building and will maintain the existing tie-in to the campus steam system. This will allow the north side to remain heated during the winter, between construction phases. The second phase will address the north half. In general, all mechanical, plumbing, electrical, and interior architectural elements on a side of the building will be addressed in the appropriate phase. The phasing of envelope improvements (aluminum storefront, overhead coiling shop doors, windows, etc.) is yet to be determined. Early phasing is preferred. The architectural plans, included in this report, visually articulate the division between phases of work.

Hazardous Materials Abatement

Assessments done for earlier work in the building confirm that lead and asbestos hazards are present. A more comprehensive study is currently underway through DFCM, but results are not yet available. Abatement operations will be required, and the cost and duration of this work should be considered in the next phase of planning and design.





SPACE PLANNING

A distinct planning effort was conducted with the following goals:

- Understand how vacated space in the building can be backfilled to enhance value to EAST and accommodate significant occupancy by WSU's Information Technology department.
- Improve classroom functionality.
- Enhance ADA compliance.

Since the initial programming effort in August 2019, WSU has further clarified who is expected to occupy the renovated space. Design of the two new buildings is also complete allowing full definition of the departments and spaces accommodated by those projects. The following space program reflects this new information. Dean Ferro and WSU's Information Technology leadership have provided input and validation of the results.

Floor plans of the existing and renovated ET building follow the space program. Many minor adjustments are made to existing components in order to accommodate new needs and improve the facility. The Architectural, Structural, Mechanical/Plumbing and Electrical sections include further discussion. The most significant changes in the plan, however, reflect a single, broad strategy to improve classroom functionality while enhancing ADA compliance. Areas with small, awkward, non-ADA compliant office groupings are renovated into larger and better proportioned classroom spaces. These larger classrooms better fit expected class sizes and allow for more efficient and flexible use of space. The displaced offices are relocated to better organized, ADA-compliant suites, primarily in the 1st floor south-east corner.

- . .

OFFICE & SUPPORT SPACES

(Colors coordinate to Floor Plans)

				Total
Dept.	Space Name	Sq. Ft.	Qty	Sq. Ft.
ET: MF	ET			
	Department Chair	150	1	150
	Faculty Offices	120	7	840
	Adjunct Faculty	40	2	80
	Reception / Admin	180	1	180
	Work Room	180	1	180
	Break Room	240	1	240
	Conference Room	250	1	250
			ent Total	1,920
ET: EL	ECTRICAL ENGINEERING		N7070-1-11	1 200
ET: EL	ECTRICAL ENGINEERING Faculty Offices Adjunct Faculty Conference Room	TECH (120 40 250	EET) 10 1 1	1,200 40 250
ET: EL	Faculty Offices Adjunct Faculty	120 40 250	N7070-1-11	40 250
	Faculty Offices Adjunct Faculty	120 40 250	10 1 1	40 250
	Faculty Offices Adjunct Faculty Conference Room	120 40 250	10 1 1	40 250 1,490
	Faculty Offices Adjunct Faculty Conference Room	120 40 250 Departm	10 1 nent Total	40 250 1,490 4,320
	Faculty Offices Adjunct Faculty Conference Room	120 40 250 Departm 120	10 1 nent Total	40 250 1,490 4,320 600
	Faculty Offices Adjunct Faculty Conference Room JS DATA CENTER Office Storage (Infrastructure)	120 40 250 Departm 120 600	10 1 nent Total	40 250 1,490 4,320 600 150
	Faculty Offices Adjunct Faculty Conference Room JS DATA CENTER Office Storage (Infrastructure) Work Space (Infrastructure	120 40 250 Departm 120 600 150	10 1 nent Total	40
	Faculty Offices Adjunct Faculty Conference Room JS DATA CENTER Office Storage (Infrastructure) Work Space (Infrastructure Common Mail Room/copy room	120 40 250 Departm 120 600 150 120 500	10 1 nent Total	40 250 1,490 4,320 600 150 120






TECHNICAL & LEARNING SPACES

(Colors coordinate to Floor Plans)

Dept.	Space Name	Sq. Ft.	Qty	Total Sq. Ft.	Occup.	Existing Room #	Notes
ENG T	ECH: MFET SHOPS						
	Plastics and Composite Lab	4,620	1	3,617		235/239/245	
	Subtractive Manuf. Lab	7,260	1	7,260		201	
	Tool Crib	165	1	165		209	
	Flammable Storage	150	1	150		215	
	CNC Lab	1,320	1	1,320	18	203/243	
	Casting Lab	1,135	1	1,135		233	
	Metal Forming	2,475	1	2,475		231	
	Additive Manuf. Lab	990	1	817		207/235A/241	
	Industrial Controls Lab	660	1	660		230	
-	Material Storage	330	1	330		213	
	Classroom	660	1	413	24	238	
	Senior Project Open Lab	263	1	263		211	
	Grinding	186	1	186		225	
	Control	118	1	118			
		epartment		18,909			
ING I	ECH: MFET LABS	1 000		4 000		220	ME has their schole in this second
	Thermal Fluids / Hydraulics	1,320	1	1,320		230	MF has their robots in this space Includes Offices, tool room, grinding room, sen. Projects fab, rack& plasma cutting, CNC plasma cutting, welding
	Welding	4,500	1	4,500		219	booth area
	Welding Consumable Storage	330	1	183		221	
	Welding Storage Shed (ext)	1,320	0	-			Request New door
	Miller Electric Storage	330	1	330			Secure room, two small pieces of
	Laser Welding Room	120	1	120		217	equipment, shielded
	Gas Bottle / Manifold	330	1	330		229/227	equipment, shielded
	Maintenance Shop	350	1	350		226	Includes Office, storage, work area
		740	1	740	30	247	Tiered classroom, near welding
-	Miller Welding Classroom	epartment		7,873	30	247	Tiered classroom, fiear weiding
	De	parunent	TULAI	7,073			
ET: EL	ECTRICAL ENGINEERING	TECH	(EE	Г)			
1.	Process Automation	2,640	1	2,640	24		Including Industrial Control Lab
	Electrical Circuit Lab	1,320	1	920	24	101A/101B	
	De	epartment	Total	3,560			
MECH	ANICAL ENGINEERING						
MECH	ANICAL ENGINEERING	1 320	1	1 320	24	120	FFT Inst I ab
MECH	Measurement & Instrumentation	1,320	1	1,320	24	120	EET Inst. Lab
MECH	Measurement & Instrumentation Classrooms	800	4	3,200	24 32	120 204/210	EET Inst. Lab
	Measurement & Instrumentation Classrooms De	800 epartment	4				EET Inst. Lab
	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI	800 epartment GN	4 Total	3,200 4,520	32	204/210	EET Inst. Lab
	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab	800 epartment GN 1,320	4 Total 2	3,200 4,520 2,640			EET Inst. Lab
	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab	800 epartment GN	4 Total 2	3,200 4,520	32	204/210	EET Inst. Lab
ENGIN	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab De	800 epartment GN 1,320	4 Total 2	3,200 4,520 2,640	32	204/210	EET Inst. Lab
ENGIN	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab De EGE IT	800 epartment GN 1,320 epartment	4 Total 2 Total	3,200 4,520 2,640 2,640	32	204/210	EET Inst. Lab
ENGIN	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab De EGE IT College IT Storage	800 epartment GN 1,320 epartment 250	4 Total 2 Total 1	3,200 4,520 2,640 2,640 250	32	204/210	EET Inst. Lab
ENGIN	Measurement & Instrumentation Classrooms De EERING: PRODUCT DESI Computer Teaching Lab De EGE IT College IT Storage College IT Work / Prep Space	800 epartment GN 1,320 epartment	4 Total 2 Total 1 1	3,200 4,520 2,640 2,640	32	204/210	EET Inst. Lab









ENGINEERING TECHNOLOGY BUILDING RENOVATION | FLOOR PLAN - LEVEL 1



WSU ET Building Renovation Feasibility and Space Planning



LEVEL 1



ENGINEERING TECHNOLOGY BUILDING RENOVATION | FLOOR PLAN - LEVEL 2




N

WSU ET Building Renovation Feasibility and Space Planning




LEVEL 2



EXISTING FLOOR PLAN - LEVEL 1







EXISTING FLOOR PLAN - LEVEL 2





ARCHITECTURE

The scope of the architectural renovation is driven in part by the disruption necessary to replace all HVAC equipment. As such, ceilings and lighting are replaced throughout the building. The renovation also strives to backfill space occupied by the people and departments that will move into the new Noorda Building, or have already moved to the College's new facility at the Davis Campus. To suit the new occupant's needs, significant sections of office and academic areas are reorganized. In these areas, all new finishes, mechanical, plumbing, and electrical elements are anticipated.

The table below articulates architectural renovations deemed to be mandatory and those that may be optional. Note that areas being reconfigured (moving walls / reorganizing space) will require all new elements regardless of indications in this table. For this reason, the cost estimate covers the replacement of all floor coverings and painting all walls. It also considers the cost to create vestibules at all major entrances, not just the three noted entrances.

For each element of work, the anticipated work phase is also indicated (Phase 1-South / Phase 2 North).

Renovation Element	Mandatory	Optional	Phase	Notes
Ceilings	Х		Both	
Existing Bathrooms	Х		Both	Includes all finishes, fixtures, partitions, etc.
Locker Room 222 to Women's	Х		1	
Restroom				
Restroom expansion into Office 115	Х		2	
150 Lockers – Distributed within Shops	Х		1	222C lockers removed. New lockers in shops
Flooring (Public Areas)	Х		Both	Lobbies, Corridors, Classrooms
Concrete Slab @ Existing 109	Х		1	
Custodial				
Flooring (Non-Public)		Х	Both	Offices, Service Areas
Painting (Public Areas)	Х		Both	
Painting (Non-Public)		Х	Both	Includes Shops
Wall Base (Public Areas)	Х		Both	
Interior door slabs	Х		Both	
Door hardware	Х		Both	
Interior Stair Railing	Х		Both	Square handrail replaced and guardrail added
Drinking Fountains	Х		Both	
Exterior Storefront Entrances &	Х		Both	Coordinated with radiant heaters at perimeter
Windows				
Add Vestibules	Х		Both	Main, 2 nd floor North and South Entrances
Add Vestibules		Х	Both	All other exterior entrances
Exterior Man Doors at Shops	Х		1	Also includes hardware
Overhead shop doors	Х		1	Includes electric operators and controls
Main West Entrance Enhancement		Х	2	Soffit and lighting above storefront
Exterior Mechanical Louvers	Х		1	Most are badly rusted
Exterior Railing at south-west entrance	Х		1	Badly corroded
Abandon roof curbs / equipment	Х		Both	Remove curbs, new deck, insulate, flat roof
Asbestos Abatement			Pre	Assessment and Work by WSU

Ceilings

Existing acoustical panel and hard-lid ceilings will be replaced in-kind with new assemblies matching WSU standards. An exception is existing Custodial Room109 where there is currently no ceiling. This space will have a new acoustical panel ceiling.

Note that high-bay shops on the east side of the 2nd level do not have ceilings and none will be added.





Interior Doors and Door Hardware

All interior door slabs and hardware are expected to be replaced. Hollow metal door frames will remain and be used in new construction.

Interior Stair Railings

The railing at the two primary stars is not code compliant. The existing handrail shall be removed and a new compliant hand and guardrail installed.

Drinking Fountains

2 existing drinking found shall be removed and replaced with a fixture similar to Elkay model EDFP19C. It is non-filtered, non-refrigerated, and is shallower than conventional fixtures. This fixture is expected to reduce its protrusion into the corridor and remove the ADA violation. Refrigerated units with a bottle filler are preferred, but the non-refrigerated unit has been approved by WSU in order to achieve ADA compliance.

Toilet Rooms

The building does not have enough water fountains or water closets and lavatories available to female occupants. The plumbing fixture code review below illustrates the deficiencies (Shown in Red). To meet code requirements, the project expects to create two additional women's restrooms (7 toilets minimum) and add 4 drinking fountains. The new restrooms will be located at existing rooms 222 and 115.

	PLUMBING FIXTURE SUMMARY													
CLASS			WATER CLOSETS LAVATORIES						LOAD		S	FOU	IKING NTAI NS	REQUIREMENTS
	IC			MA	MALE FEMALE		MALE FEMA		EMALE D		DF	ΞQU		
OCCUPANCY	OCCUPANCY	AREA	OCCUPANT	REQ	PROV	REQ	PROV	REQ	PROV	REQ	PROV	REQ	PROV	OTHER RE
		9,948 SF	0											
Assembly	A-3	3,155 SF	158	1	17	2	5	1	7	1	3	1	*7	1 Service Sink
Business	В	50,427 SF	1059	12	17	12	5	8	7	8	3	11	*7	1 Service Sink

* Including 2 Break Rooms.

Existing toilet rooms will be renovated to create ADA compliant, contemporary facilities. All finishes, plumbing fixtures, lighting, toilet partitions and counters will be removed and replaced.

Exterior Storefront windows and entrances

All existing aluminum doors and windows will be replaced with high performance, thermally broken storefront systems and new double-pane glass assemblies. The phasing of this work is still to be determined and is dependent on funding and construction methods related to the removal of heating units below many windows.





Public entrances to the building do not currently have vestibules. Per the plans, space for new vestibules is available, and new aluminum storefront systems will be constructed to create vestibules at each entrance.

Exterior Man-Doors at Shops

4 exterior grade hollow metal doors, frames, and related hardware will be replaced.

Overhead Coiling Shop Doors

5 high-R value metal coiling doors will replace all existing coiling doors. Seals and electric operators also require replacement.

Main West Entrance Enhancements

In addition to replacing the existing storefront and creating an interior vestibule, the soffit and lighting at the entrance will be replaced and a new custom entrance canopy installed.

Exterior Stair Railing

A deteriorated railing at the south-west corner of the building will be replaced with a stainless-steel railing.

Interior Walls

CMU, metal stud and wood stud walls are being demolished. All new walls will be standard metal stud construction. Walls between offices and around classrooms will require sound insulation. There are no instances of structural sheer walls or bearing walls being removed. However, the Structural narrative articulates work required to create door or passageway openings in existing CMU walls at 5 locations on level 1.







STRUCTURAL

General Design Criteria:

Risk Category: III Dead Loads: As required Floor Live Loads:

- 80 psf at offices, classrooms, labs, corridors above first floor
- 2500 pound concentrated load

Flat Roof Snow Load:

- Pg: 46 psf
- Pf: 36 psf

*Use owner requested Pf:40 psf with consideration for drifting snow

There are five locations on level one where it has been proposed to either add wall openings or increase the size of existing openings;

- The entrance to the unisex restroom on gridline 3, between N and P needs to be relocated to the north.
- The two corridor entrances on gridline 3 at approximately gridline N and L.5, respectively, need to be enlarged to accommodate sidelights.
- The corridor entrance on gridline 2 at approximately gridline 3 needs to be enlarged to accommodate a sidelight.
- The east-west wall on approximately gridline M.5, between gridlines 1 and 2 is proposed to be modified by infilling the existing two openings with masonry and creating one new opening for a new north-south corridor.

These modifications are allowed and can be structurally justified using the provisions of the 2018 International Existing Building Code; Section 806.3; where the alterations will not decrease the capacity of existing elements by more than 10 percent.





MECHANICAL & PLUMBING

Project Description

The existing Engineering Technology building is intended to undergo a major renovation of mechanical systems. Plumbing changes will be made to accommodate the remodel work, and fire protection systems will be updated. The goal is to bring the building mechanical systems up to date and to extend its life by another 30 years.

MECHANICAL SYSTEMS

Water Source VRF:

The HVAC system shall be designed in conformance with the Campus Master Plan, which mandates that buildings are served by the existing central cooling tower loop that is the source for all cooling and heating demand.

This will be achieved with a water-cooled Variable Refrigerant Flow (VRF) system.

- Manufacturer will be Mitsubishi supplied by Applied Product Solutions.
- The system will be capable of simultaneous heating and cooling.
- Each office, classroom, lab, and shop space will be zoned independently.
- Performance requirements of the VRF system are as follows:

Mode	ECWT	Performance
Cooling	77	12.0 EER
Heating	50	3.6 COP

Construction Phase 1

- The south portion of the building includes offices, classrooms, labs, manufacturing shop spaces, and space for the campus IT center.
- There are approximately 55 temperature control zones in Phase 1. Each temperature control zone will have a ceiling cassette fan coil unit. Ducted fan coil units will only be used when the ceiling height is not appropriate for a cassette fan coil.
- Make-up air and ventilation air will be provided in the metal forming, plastics manufacturing, and welding shop spaces using dedicated make-up air units located in the mechanical mezzanines. Space conditioning will be provided by ducted VRF fan coil units.
- Phase 1 will include 12 twinned heat pumps.
 - Heat Pumps 1-4: 96 MBH each to provide a total of 348 MBH for offices, classrooms, labs, and campus IT.
 - Heat Pump 5-6: 336 MBH each to provide a total of 672 MBH for MAU-1.
 - Heat Pump 7-8: 168 MBH each to provide a total of 336 MBH for MAU-2.
 - Heat Pump 9-10: 144 MBH each to provide a total of 288 MBH for MAU-3.
 - Heat Pumps 11-12: 240 MBH each to provide a total of 480 MBH for DOAS-1.

Construction Phase 2

 The north portion of the building includes offices, classrooms, labs, and manufacturing shop spaces.





- There are approximately 40 temperature control zones in phase 2. Each temperature control zone will have a ceiling cassette fan coil unit. Ducted fan coil units will only be used when the ceiling height is not appropriate for a cassette fan coil.
- Phase 2 will include 6 twinned heat pumps.
 - Heat Pumps 13-16: 72 MBH each to provide a total of 288 MBH for offices, classrooms, and labs.
 - Heat Pumps 17-18: 312 MBH each to provide a total of 624 MBH for ERV-1.

Ventilation Equipment:

Existing main ductwork will be reused as much as possible for new ventilation and exhaust air streams. New branch ductwork will need to be routed to individual fan coils in each zone.

Construction Phase 1

- DOAS-1 will be installed in the South Mechanical Room 117 to provide outdoor air to the classrooms and offices in this phase. This unit will provide some of the make-up air for baseline shop exhaust rates. The existing air handler, AC-2, and the associated relief fan will be demolished.
- The existing air handlers (AH-2, 3 & 4) that serve the Welding, Metal Forming and Plastic Shops will be demolished and replaced with make-up air units (MAU-1, 2 & 3). These units will be sized to make-up air as point use exhaust is turned on throughout each shop. The existing air handlers are not sized to make-up the total exhaust rate for each shop due to equipment diversity. The new make-up air units will be sized similarly.
 - Standard 36" x 80" doors provide access to these mezzanine equipment rooms. Based on preliminary MAU shipping split dimensions, a larger opening will need to be made to move units into rooms.
- The existing gas fired rooftop unit that serves Miller Welding Class Lab 247 will be demolished and the ventilation requirement will be served by DOAS-1.
- The existing gas fired make-up air unit that serves Composite Lab 245 paint booths will be demolished.
- Equipment Models
 - DOAS-1 7,000 cfm Swegon SD 40 with refrigerant coil section
 - MAU-1 (Welding Shop) 10,000 cfm Swegon SD 50 with refrigerant coil section
 - MAU-2 (Metal Forming Shop) 5,000 cfm Swegon SD 30 with refrigerant coil section
 - MAU-3 (Plastics Shop) 4,000 cfm Swegon SD 25 with refrigerant coil section

Construction Phase 2

- ERV-1 will be installed in the North Mechanical Room 107 to provide outdoor air to North part of the building, including shop spaces. This unit will serve the general exhaust requirement for the North part of the building, including restroom group 222. This unit will serve the constant exhaust requirement for the shop spaces in this phase. The existing air handler, AC-1, and the associated relief fan will be demolished.
- The existing air handler (AH-1) that serves the Subtractive Manufacturing Lab 201 will be demolished.
- Equipment Models
 - ERV-1 9,000 cfm Swegon RX 60 with refrigerant coil section

Exhaust Equipment:

In both phases there will be some existing fans that will be demolished and some will be replaced with new fans. There will be fans added in phase 1. See below for the summary and quantities:





Construction Phase 1

- Demolished: 7
- Demolished/Replaced: 13
 - (2) 5 HP
 - (6) 1 HP
 - (5) Fractional HP
- Added: 6
 - (1) 5 HP
 - (1) 1 HP
 - (4) Fraction HP

Construction Phase 2

- Demolished: 2
- Demolished/Replaced: 1 (fractional HP)

The Plastic Manufacturing Lab dust collection fan has been described as not having enough capacity for dust collection. (3) devices will be removed from the system and the ductwork will be cut and capped for future use. A VFD and duct pressure controls will be added to the dust collection system to all fan to modulate as the demand changes. A duct will be extended into CNC Lab 243 for future connection.

Condenser Water in Tunnel:

The chilled water piping that currently serves the building will be utilized for condenser water for the water-source VRF system. Ultimately, the section of pipe that runs through this tunnel will serve large areas of campus and will need to be replaced. All new piping will be polypropylene, manufactured by Niron.

Construction Phase 1

Use existing chilled water piping in the tunnel that runs past the north half of the building. South
of where the steam piping enters the north mechanical room and where there is more space in
the tunnel, transition piping to 18" supply and return piping. Terminate piping after the
connection to the south mechanical room with a double-offset butterfly valve and blind flange.

Construction Phase 2

 Demolish existing chilled water piping between phase 1 piping and the connections installed as work of the Noorda Engineering project in 2020 and install 18" supply and return piping.

Piping Demolition in Tunnel

In addition to the phased demolition of the existing chilled water piping, the existing steam, condensate return and natural gas piping will be demolished back to the tunnel junction to the north in phase 2 of this project.





PLUMBING SYSTEMS

Restroom Modifications:

The size and designation of all restrooms in the building will be modified. Existing plumbing fixtures and piping will be decommissioned and demolished to accommodate new restroom layouts. See architectural section for fixture quantity requirements.

Construction Phase 1

- The existing level 1 men's restroom on the south end of the building will be converted into two gender neutral restrooms.
- The existing level 2 toilet room will be converted into a larger women's restroom.
- The existing level 2 men's restroom and locker room will be converted and expanded into a men's and women's restroom.

Construction Phase 2

• The existing level 1 north restrooms will be expanded.

The Plastics Manufacturing Lab currently has a single low-capacity water cooled chiller that serves to cool a mold machine. The chiller is served by the domestic water and the leaving water is discharged into a nearby roof drain line. An additional similar chiller is planned to be added soon. A domestic water line will be provided to serve this chiller and the new and existing drain will be routed to an appropriate location. During design it will be investigated if condenser water could be used to connect to the chillers as an alternative.









- CAMPUS DATA CENTER
- COLLEGE IT
- ELECTRICAL ENGINEERING
- MANUFACTURE ENGINEERING
- MECHANICAL ENGINEERING
- PRODUCT DESIGN
- UNASSINGED








- CAMPUS DATA CENTER
- COLLEGE IT
- ELECTRICAL ENGINEERING
- MANUFACTURE ENGINEERING
- MECHANICAL ENGINEERING
- PRODUCT DESIGN
- UNASSINGED









ELECTRICAL

CONSTRUCTION PHASE I - SOUTH PORTION OF BUILDING

Power Distribution System

- Existing 750KVA medium voltage transformer will remain in place.
- A new 1200-amp., 277/480-volt main distribution switchboard will be installed in the north part of the building to provide power to the new distribution panelboards in the north and south portions of the building.
- New main distribution panelboards will be installed in the old mechanical room to distribute power to all 277/480-volt branch panelboards and to 120/208-volt panelboards through dry type, stepdown transformers.
- A new dry type transformer will be installed to step the voltage down from 480-volt to 120/208-volt.
- A new 120/208-volt main distribution panelboard will be installed on south part of the building to provide power to all 120/208-volt branch panelboards.
- All existing branch panelboards 277/480-volt and 120/208-volt will be replaced with new.
- Surge protective devices will be provided for new main distribution switchboard and main distribution panelboards.
- 277/480-volt panelboard will be installed in south mechanical room to provide power to new large mechanical equipment.
- A 120/208-volt panelboard will be installed to provide power to all new fan coil units and small mechanical equipment.
- All feeder conductors to branch panelboards will be replaced with new ones.
- Bus ducts and branch circuits in the shops and labs will remain.
- New devices will be installed in all new rooms and circuited to nearest branch panelboards.
- All devices on exterior walls, which are being furred out, will be removed and new devices will be installed in the new walls and circuited to nearest branch panelboards.
- Existing electrical power metering will need to be moved to new switchboard and tied to campus network.
- Minimum of 25% spare capacity will be provided in all electrical panelboards.
- Existing grounding electrode from old electrical switchboard needs to be removed and tied to new main distribution switchboard. Neutral and ground strap in existing switchboard needs to be removed.
- Ground fault protective receptacles will be installed within proximity of sinks, mechanical room, etc. to meet requirement of National Electrical Code (NEC).
- Power will be provided to irrigation system.
- Existing emergency panelboards are to remain and utilized for new emergency circuits.

Exterior Lighting

- Power shall be maintained to all exterior light poles and canopy lights. Provide temporary power to keep these lights on during construction, as necessary.
- All under canopy light fixtures will be replaced with new LED light fixtures.
- Emergency lights will be provided by all exterior stairs, ramps, etc. to meet NFPA code.

Interior Lighting and Control

- All interior light fixtures are to be removed including j-boxes, conduit, conductors, etc. Home runs can be utilized for new LED light fixtures.
- New LED light fixtures to meet WSU standards.



WSU ET Building Renovation Feasibility and Space Planning



- Light level in all areas will be in accordance with IESNA recommendations except in a few labs that require a higher illumination light level.
- Color temperature of all light fixtures will be 5000K.
- Lighting energy load shall be less than .5 watts/sf.
- Emergency light will be provided in all the corridors, restrooms, large shops, labs, classrooms, electrical rooms, MDF and IDF rooms, etc. All emergency lights will be tied to existing emergency/life safety panelboard such as when commercial power fails the come on automatically.
- All interior room's light fixtures will be controlled either with wall occupancy sensors or ceiling occupancy sensors to maximize on energy saving.
- Daylight harvesting will be provided for large rooms with windows as required by energy code.
- Dimmer capability will be provided for all the rooms except corridors, restrooms, mechanical rooms, electrical rooms, MDF and IDF rooms, etc.
- The entire building lighting load will be controlled by occupancy sensors.
- This building will be totally black when it is not occupied.

Fire Alarm System

- New addressable fire alarm system will be installed in the entire building to meet NFPA.
- Speaker/strobes will be installed throughout the building.
- All magnetic door holders will be tied to fire alarm control panel for automatic release during fire alarm.
- Duct detectors will be installed for air handling units with 2000 cfm and above. Duct detectors shall be tied to fire alarm control panel for automatic shut down during fire alarm.
- All fire/smoke dampers will be tied to fire alarm control panel for automatic closing during detection of fire.
- New fire alarm system will be tied to the WSU campus fire alarm network.

Radio Communication Enhancement System (BDA System)

- Study needs to be done to see if BDA system is needed for this building. We recommend this
 system to be installed to cover the lower level of the building as a minimum.
- BDA system will be tied to FACP.

Communication System

- Existing MDF room under phase I needs to be operational to keep the network system to phase II devices.
- All existing data cables will be removed. New data cables will be installed for all data jacks.
- Raceways, boxes, and cable trays will be installed throughout the building to accommodate the installation of network cabling, jacks, equipment, etc.
- New ground bus bar will be installed in the MDF room and will be tied to main grounding system for the building with #2 THHN ground cable.
- New WAP's will be installed on exterior walls and locations will be coordinated with WSU IT groups. #6 AWG grounding will be provided for all exterior WAP's.

Security System

- Conduit, boxes will be provided for security devices throughout the building. WSU will install all security devices, card readers, cabling, equipment, etc.
- Communication cable tray will be utilized for all security cables.



WSU ET Building Renovation Feasibility and Space Planning



- All labs exterior doors will be protected with security card access system.
- New cameras will be installed by entrances and other spaces as directed by WSU. Conduit will be provided for cameras and will run to nearest cable tray.

A/V System

- A/V system will be provided in all classrooms, conference rooms, labs, etc.
- All cabling, connectors, jacks, boxes, touch panels, etc. will be coordinated with WSU A/V group.

CONSTRUCTION PHASE 2 - NORTH PORTION OF BUILDING

Power Distribution System

- The new 1200-amp., 277/480-volt main distribution switchboard which was installed under phase I will be utilized to provide power to the new distribution panelboards in the north portion of the building.
- New main distribution panelboards will be installed in the old mechanical room to distribute power to all 277/480-volt branch panelboards and to 120/208-volt panelboards through dry type, stepdown transformers.
- A new dry type transformer will be installed to step the voltage down from 480-volt to 120/208-volt.
- A new 120/208-volt main distribution panelboard will be installed on north part of the building to provide power to all 120/208-volt branch panelboards.
- All existing branch panelboards 277/480-volt and 120/208-volt will be replaced with new.
- Surge protective devices will be provided for new main distribution switchboard and main distribution panelboards.
- 277/480-volt panelboard will be installed in north mechanical room to provide power to new large mechanical equipment.
- A 120/208-volt panelboard will be installed to provide power to all new fan coil units and small mechanical equipment.
- All feeder conductors to branch panelboards will be replaced with new ones.
- Bus ducts and branch circuits in the shops and labs will remain.
- New devices will be installed in all new rooms and circuited to nearest branch panelboards.
- All devices on exterior walls, which are being furred out, will be removed and new devices will be installed in the new walls and circuited to nearest branch panelboards.
- Minimum of 25% spare capacity will be provided in all electrical panelboards.
- Ground fault protective receptacles will be installed within proximity of sinks, mechanical room, etc. to meet requirement of National Electrical Code (NEC).
- Existing emergency panelboards are to remain and utilized for new emergency circuits.
- 30-amp. receptacles will be provided in MDF room and will be tied to emergency and normal power per WSU IT requirements.

Exterior Lighting

- Power shall be maintained to all exterior light poles and canopy lights. Provide temporary power to keep these lights on during construction, as necessary.
- All under canopy light fixtures will be replaced with new LED light fixtures.
- Emergency lights will be provided by all exterior stairs, ramps, etc. to meet NFPA code.



WSU ET Building Renovation Feasibility and Space Planning



Interior Lighting and Control

- All interior light fixtures are to be removed including j-boxes, conduit, conductors, etc. Home runs can be utilized for new LED light fixtures.
- New LED light fixtures to meet WSU standards.
- Light level in all areas will be in accordance with IESNA recommendations except in a few labs that require a higher illumination light level.
- Color temperature of all light fixtures will be 5000K.
- Lighting energy load shall be less than .5 watts/sf.
- Emergency light will be provided in all the corridors, restrooms, large shops, labs, classrooms, electrical rooms, MDF and IDF rooms, etc. All emergency lights will be tied to existing emergency/life safety panelboard such as when commercial power fails the come on automatically.
- All interior room's light fixtures will be controlled either with wall occupancy sensors or ceiling occupancy sensors to maximize on energy saving.
- Daylight harvesting will be provided for large rooms with windows as required by energy code.
- Dimmer capability will be provided for all the rooms except corridors, restrooms, mechanical rooms, electrical rooms, MDF and IDF rooms, etc.
- The entire building lighting load will be controlled by occupancy sensors.
- This building will be totally black when it is not occupied.

Fire Alarm System

- New addressable fire alarm system will be installed in the entire building to meet NFPA.
- Speaker/strobes will be installed throughout the building.
- All magnetic door holders will be tied to fire alarm control panel for automatic release during fire alarm.
- Duct detectors will be installed for air handling units with 2000 cfm and above. Duct detectors shall be tied to fire alarm control panel for automatic shut down during fire alarm.
- All fire/smoke dampers will be tied to fire alarm control panel for automatic closing during detection of fire.

Radio Communication Enhancement System (BDA System)

 BDA system will be installed in north part portion of the building and will be tied to new system which was installed under phase I.

Communication System

- New power will be provided for new racks in the MDF room.
- All existing data cables on north portion of the building will be removed. New data cables will be installed for all data jacks.
- Raceways, boxes, and cable trays will be installed in north part of the building to accommodate the installation of network cabling, jacks, equipment, etc.
- New WAP's will be installed on exterior walls and locations will be coordinated with WSU IT groups. #6 AWG grounding will be provided for all exterior WAP's.





Security System

- Conduit, boxes will be provided for security devices throughout the building. WSU will install all security devices, card readers, cabling, equipment, etc.
- Communication cable tray will be utilized for all security cables.
- All labs exterior doors will be protected with security card access system.
- New cameras will be installed by entrances and other spaces as directed by WSU. Conduit will be provided for cameras and will run to nearest cable tray.


A/V System


- A/V system will be provided in all classrooms, conference rooms, labs, etc.
- All cabling, connectors, jacks, boxes, touch panels, etc. will be coordinated with WSU A/V group.

Drawings are included as an appendix to this report.
















FIRST FLOOR PLAN NORTH - PANELS SCALE: 1/8" = 1-0"

L X 375 WEST 200 SOUTH SALT LAKE CITY, UT 84101 P 801.521.8600 F 801.521.7913 www.gsbsarchitects.com STUDY FEASIBILITY . . BUILDING UNIVERSIT NOLOGY | WEBER STATE (OGDEN, UTAH ENGINEERING TECHNOL 30 YEARS IN B 939 S. West Temple SLC, UT 84101 Phone : 801.521.8007 Email : Admin@ccconline.com ECE Project # 5613 ECE PROJECT NO. 5613 ISSUED: NO. DATE DESCRIPTION 2021.03.09 FEASIBILITY STUDY REVISIONS: NO. DATE DESCRIPTION FIRST FLOOR PLAN NORTH -PANELS PHASE II SHEET NUMBER EP1.1

COST ESCALATION AVERAGE FOR 2021



	ENR 20 City	RLB SLC	MCI	TCI	AVERAGE
2016	3.50%	4.41%	4.78%	5.81%	4.56%
2017	3.56%	5.00%	5.55%	5.58%	4.91%
2018	3.34%	8.50%	8.10%	6.17%	6.87%
2019	1.86%	4.21%	5.89%	4.69%	4.15%
2020	3.89%	0.03%	-0.57%	-1.51%	0.37%
5 YEAR AVERAGE	3.23%	4.43%	4.75%	4.14%	4.17%

Weber State University – Standard OPR

Site Selection

1. Building orientation needs to have a detailed discussion early in programming and design.

Alternative Transportation

- 1. All new construction should have new electric vehicle charging stations.
 - a. One dual-port station shall be installed per new building; in addition, capacity for up to 6 stalls (3 dual port charging stations) shall be installed. This will include conduit out to ground box locations. Conduit shall be a minimum of 2 inch. This shall be included in the base bid of construction.
- 2. All new construction should look at options for bike racks near the facility. (consider the option for covered bike racks)
- 3. Bollards and signage for EV charging station should be considered and designed for the site.

Stormwater

- 1. Consider the use of bio-swells and maximize stormwater detention/filtration at building site.
- 2. Become familiar with and follow guidelines outlined in WSU's SWMP (latest is located at EH&S website)
- 3. Consider the use of Low Impact Development (LID) and maximize stormwater detention/filtration at buildings on sites over an acre. LID's must retain one inch of water of footprint of disturbed construction area, this will be mandatory from state starting 2020
- 4. Connect all storm water lines to retention pond.
- 5. Verify if site will be over, or under an acre. If site is over an acre, obtain a SWPPP.

Heat Island

- Roof shall be a white membrane roof with a minimum 25 year warranty and an albedo > 0.65.
- 2. Discuss strategies to reduce heat island effect given site conditions.

Light Pollution

- 1. No uplighting.
- 2. All parking lot lighting and athletic lighting will be full cut off LED.

Water Use Reduction

- 1. 0.5 gpm lavatories. Basis of design Moen 8211 faucet and All lavatories, toilets urinals, and shower heads need to be EPA WaterSense certified.
- 2. Dual flush toilets (1.1 and 1.6 gpf) or 1.28 gpf flush valve
- 3. Low flow urinals and flush valves (0.125 gpf).
- 4. No sensor or automated operation flush valves.
- 5. Low flow shower heads (1.5 gpm)
- 6. Auto shut off valve for domestic water tied to meter.

WSU Standard OPR

- 7. Non-filtered bottle filling stations. Elkay EZ H2O
- 8. Design consideration for water running down faucet neck to prevent water on floor.

Water Efficient Landscaping

- 1. Discuss xeriscaping and the use of native plants.
- 2. Automated Rainmaster system.
- 3. Install Auto flush filter Amiad Filtamat, or equivalent.
- 4. Use Pedestal Rainmaster DX3 controller.
- 5. Low flow heads, Hunter MP's preferred
- 6. DU of 70%, or better tested by WSU before N.O.T is obtained.
- 7. Drip in all non-turf areas with operational indicator flags. Netafim, or point source drip irrigation to be used. Netafim preferred with flags
- 8. No turf in areas with less than 6 feet
- 9. On steep grades used terraced planter beds.
- 10. Plan for snow removal, where snow will be plowed to for the roads and parking lots as well as sidewalks. Install salt tolerant plants in these areas.
- 11. Become familiar with and follow WSU's Division 2 Standards.
- 12. Electromagneting, or ultrasonic Meter installed after filter

Metering

- 1. Domestic Water Meter shall be installed on main water feed to building.
- 2. Electric meter shall be installed on or near MDP. Generally speaking, a single meter for the entire building shall be sufficient; however, sometimes in certain applications it may make sense to sub-meter mechanical and lighting. This shall be determined during sustainability charrette for the project.
- 3. BTU meter shall be installed for chilled/condenser water.
- 4. All meters shall be connected to BuildingOS system (LUCID). Specification and drawings need to clearly indicate who is responsible for this and how it shall be done.

Energy – Lighting

- 1. 5000K color interior and exterior.
- 2. All LED lighting.
- 3. Efficacy of 110 or greater on all light fixtures.
- 4. 0.5 watts/sqft target.
- 5. Minimize types of light fixtures (we want a small list on the lighting fixture schedule)
- 6. Occupancy sensors throughout the building (programmed for vacancy sensing)
- 7. Dark building All emergency lights are connected to occupancy sensors through a GTD.
- 8. No lighting control panels.
- 9. Exterior lighting controlled by photocell at building site.
- 10. Recommended Illumination Levels
 - 1. 10 20 Foot Candles Corridors, Vesitbules, Stairwells, Common Areas, Locker Rooms, Lounges.
 - 2. 20 40 Foot Candles Classrooms, Offices, Conference Rooms, Computer Labs.
 - 3. 30 50 Foot Candles Kitchens, Shops, Labs, Art Studios

- 11. No photocells (daylight harvesting) in classrooms or offices. Only in large open public spaces.
- 12. All offices and classrooms will have dimmers.
- 13. Lighting control is the Wattstopper DLM series as basis of design.
- 14. Classrooms shall have lighting control at entrance and at teaching console. Lighting controls are not connected to the AV system.

Electrical

- 1. Buildings are to be looped into campus.
- 2. Oakenite armored or Prysmiam cable as basis of design for medium voltage.
- 3. Cooper switchgear with VFI as basis of design.
- 4. Fault indicators on all medium voltage lines.
- 5. Discuss options for battery backup vs generator and minimizing loads on e-power.
- 6. Power factor to be above .90.
- 7. Document (high POT or VLF) to be provided in Cx record.
- 8. Verify all gaskets sealings on transformers and medium voltage switches are at factory torch rating.

Mechanical System

- 1. Water cooled VRF Mitsubishi with 10 year warranty.
- Oversized pipes serving compressors (manifold style) eliminate need for balancing if possible.
- 3. Booster pumps shall be 20% oversized for total gpm requirement.
- 4. ERV system with no excess ventilation.
- 5. ERV will have a duct heater.
- 6. Every room gets its own T-stat.
- 7. Hybrid heatpump water heater for domestic hot water Rheem basis of design.
- 8. Twinned condenser units.
- 9. No return air systems.
- 10. Only exhaust fan is in the ERV duct all exhaust to ERV.
- 11. AE-200 devices will be included.
- 12. Pressure Testing
- 13. All motors over 2 HP are to be on VFDs
- 14. VFDs will be Mitsubishi (APS has a special WSU pricing we will only pay the price they quote)
- 15. VFDs will be specified electrical engineer and provided by electrical contractor.
- 16. Filter sizes 24" x 24" x 2" on ERVs.
- 17. Extra set of washable filters for all cassette units.
- 18. Utilize ceiling cassette VRF units wherever possible.
- 19. Ducted VRF units shall have filters in the return grill that fit in the ceiling grid and are accessible from the space side of the return grill.
- 20. VRF refrigerant piping shall be coordinated with manufacturer, so that piping can/shall be installed as drawn. Pre-determine port locations.

- 21. At least 2 extra ports shall be included on branch controllers. Extra ports shall not just be at the end of the branch controller, shall be spaced intermittently.
- 22. Maximize energy recover of VRF branch controllers by having either south and east exposures or north and west exposures on the same branch.
- 23. All domestic hot water recirculation must be located within 6 feet of point of use. Every point use will have its own mixing valve, no central mixing valves.
- 24. Pipe chases shall be 3 feet width or greater.
- 25. Non-filtered bottle filling stations. Elkay EZ H2O
- 26. Extra space in mechanical room for building growth.
- 27. Epoxy coating of all mechanical room floors.
- 28. Temperature display and control for VRF shall be done from T-stat, no return air controlling.
- 29. Filter changes at substantial completion, and post occupancy (after cleaning).
- 30. Primary, and Secondary backflow protection devices shall be of the RP type.
- 31. All chemical mixing stations shall be piped.
- 32. Provide secondary water feed for all custodial chemical stations.

Structural/Architectural

- 1. 2x2 ceiling grid. Minimize use of hard lid ceilings.
- 2. Solarban 70 XL Atlantica basis of design for glass.
- 3. Minimize use of storefront systems.
- 4. Maximum of 30% glass on building envelope. 25% or less preferred if possible.
- 5. Orientation of the glass to be primarily on the north and east sides of the building. Minimize west facing glass.
- 6. Building roof shall be prepped for solar installation.
- 7. Balconies or roof paver areas must be physcially restricted from access to the rest of the roof.
- 8. Roof shall have walkoff pads for anticipated solar layout and equipment. Walk off mats shall be white diamond pattern.
- 9. All paints and stains to be semi-gloss water based zero-VOC.
- 10. Standard is 5 paint colors (this includes Weber purple and white)
- 11. Rollers shades shall be manual if control mechanism is accessible.
- 12. Permanently attached ladder access to all roofs of the building. Ladders shall have ladder cages if possible. Hoist point and grab bar. No ship's ladders!!
- 13. Epoxy coated mechanical room floors.
- 14. Door closers
 - a. ADA Door closers must be electromechanical, (full cast iron closer, all weather fluid, meets ANSI grade)
 - b. A schedule shall be in the drawings showing door closers matched to door type and weight.
 - c. No in-ground door closers.
 - d. No concealed door closers.

Owner's Documentation

- 1. Fill in online file tree provided
- 2. Installation manuals will be in the Maintenance folder for each system/equipment.

Materials

- 1. Discuss use of recycled, locally-sourced and third party green verified materials.
- 2. Carpet tile with loc-dot technology as basis of design. Preferred 2x2 tile.
- 3. A waste management plan must be included in the design drawings. (including recycling and waste container locations)
- 4. Discussion shall be had regarding composting opportunities.
- 5. 75% of construction waste shall be diverted from the landfill.
- 6. Low-VOC sealants and caulks.
- 7. Low-VOC product discussion.

WSU Deferred Assets

Report Date

9/16/2021

02240				
	02240 ENGINEER	ING TECHNOLOGY (E	Τ)	
09082	HVAC \$1,267,			
09087		\$74,886.00		
09107 20412	HVAC Piping ET HVAC PIPING BLACK IRON PIPE	\$74,886.00	\$74,886.00	
20412	Service Life 40.00 Install Year	• •	2017 Remaining Life	-4.44
		Asset Group Remaining Life	-4.44	
09088	Controls System \$2	Tier 2 - Remaining Life 262,101.00	-4.44	
09000	Controls	202,101.00	\$262,101.00	
20415	ET CONTROLS SYSTEM PNEUMATIC	I \$262,101.00	· , · · · · · ·	
	Service Life 15.00 Install Year		Life internating Ene	-21.44
		Asset Group Remaining Life Tier 2 - Remaining Life	-21.44 -21.44	
09089	Air Distribution \$2	274,571.00	2	
09110	Duct System		\$274,571.00	
20420	ET DUCT SYSTEM LOW PRESSURE S			
20419	Service Life 30.00 Install Year ET DUCT SYSTEM HIGH PRESSURE 3		2007 Remaining Life	-14.44
	Service Life 30.00 Install Year		2007 Remaining Life	-14.44
		Asset Group Remaining Life	-14.44	
09090	HVACR Equipment	Tier 2 - Remaining Life 556,300.00	-14.44	
09111	AHU		\$563,200.00	
AH0127	AIR HANDLER COMPUTER ROOM	\$60,000.00		
AH0132	Service Life 40.00 Install Year AMERICAN AIR FILTER, AIR HANDLEF		2017 Remaining Life	-4.24
A10132	Service Life 30.00 Install Year		2007 Remaining Life	-14.43
AH0131	AMERICAN AIR FILTER, AIR HANDLEF	R \$54,000.00		
AH0129	Service Life 30.00 Install Year AMERICAN AIR FILTER, AIR HANDLEF		2007 Remaining Life	-14.43
A110129	Service Life 30.00 Install Year		2007 Remaining Life	-14.43
AH0128	AMERICAN AIR FILTER, AIR HANDLEF		5	
4110420	Service Life 30.00 Install Year		2007 Remaining Life	-14.43
AH0130	AMERICAN AIR FILTER, AIR HANDLEF Service Life 30.00 Install Year		2007 Remaining Life	-14.43
AH0133	AIR HANDLER S. DUAL DUCT	\$127,500.00		11.10
4110400	Service Life 30.00 Install Year		2007 Remaining Life	-14.43
AH0126	AIR HANDLER COMPUTER ROOM Service Life 30.00 Install Year	\$18,000.00 1990 Replacement Year	2020 Remaining Life	-1.42
		Asset Group Remaining Life	-12.93	ı.⊣ r∠
09112	Fans	_	\$26,000.00	

FA0110	JENN AIR, EXHAUST FAN 23		\$400.00			
1 AUTTO	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0092	EXHAUST FAN 2		\$400.00		rtomaning Ero	
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0100	JENN AIR, EXHAUST FAN 13	4077	\$400.00	0000		4 4 7 4
FA0105	Service Life 30.00 Install Year JENN AIR, EXHAUST FAN	1977	Replacement Year \$400.00	2006	Remaining Life	-14.74
170100	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0107	JENN AIR, EXHAUST FAN 20		\$2,500.00		rtomaning Ero	
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0109	A.O. SMITH, EXHAUST FAN 22	1077	\$500.00	2006		4 4 7 4
FA0113	Service Life 30.00 Install Year JENN AIR, EXHAUST FAN 26	1977	Replacement Year \$400.00	2006	Remaining Life	-14.74
1710110	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0114	EXHAUST FAN 27		\$400.00			
-	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0103	JENN AIR, EXHAUST FAN 16	1977	\$400.00	2006	Demosiusium Life	11 71
FA0098	Service Life 30.00 Install Year JENN AIR, EXHAUST FAN 11	1977	Replacement Year \$400.00	2000	Remaining Life	-14.74
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0096	JENN AIR, EXHAUST FAN 7		\$400.00		_	
F40000	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0099	JENN AIREXHAUST FAN 12 Service Life 30.00 Install Year	1977	\$400.00 Replacement Year	2006	Remaining Life	-14.74
FA0111	EXHAUST FAN 24	1011	\$2,500.00	2000		17.77
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0090	RETURN FAN	4077	\$2,500.00	0000	–	4 4 7 4
FA0093	Service Life 30.00 Install Year EXHAUST FAN 4	1977	Replacement Year \$400.00	2006	Remaining Life	-14.74
170000	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0102	EXHAUST FAN 15		\$400.00			
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0112	JENN AIR, EXHAUST FAN 25	1077	\$7,000.00	2006		4 4 7 4
FA0106	Service Life 30.00 Install Year JENN AIRE, EXHAUST FAN 19	1977	Replacement Year \$400.00	2006	Remaining Life	-14.74
1710100	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0089	CHAMPION, RETURN FAN		\$2,500.00			
-	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0097	JENN AIR, EXHAUST FAN 8	1977	\$400.00	2006	Demosinine Life	-14.74
FA0104	Service Life 30.00 Install Year JENN AIR, EXHAUST FAN 17	1977	Replacement Year \$400.00	2000	Remaining Life	-14.74
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
FA0108	JENN AIR, EXHAUST FAN 21		\$2,500.00			
	Service Life 30.00 Install Year	1977	Replacement Year	2006	Remaining Life	-14.74
09114	Air Compressors	Asset	Group Remaining Life	\$2,000.	-14.74 00	
CP0025	CONTROL AIR COMPRESSOR		\$2,000.00	Ψ <u></u> ,000.		
0.0020	Service Life 20.00 Install Year	1977	Replacement Year	1997	Remaining Life	-24.43
			Group Remaining Life	,	-24.43	

09115	Air Conditioning Units				\$18,000.0	0		
20434	ET AIR CONDITIONING UN	ITS CONDE		\$18,000.00				
	Service Life 20.00	Install Year	1999 Asse	Replacement Year t Group Remaining Life	2019	Remaining Life -2.42	-2.42	
09124	Heat Exchangers			- 1 5	\$17,100.0	0		
20435	ET HEAT EXCHANGERS S	TEAM TO HE		\$17,100.00				
	Service Life 30.00	Install Year	1977 Asse	Replacement Year t Group Remaining Life	2007	Remaining Life -14.43	-14.43	
09126	Fan Coil/Terminal Unit				\$30,000.0	0		
FCU0051	NELSON, FAN COIL UNIT			\$2,000.00				
FCU0046	NELSON AIRE, FAN COIL L		1977	Replacement Year \$2,000.00	1996	Remaining Life	-24.74	
FCU0050	NELSON, FAN COIL UNIT	Install Year	1977	Replacement Year \$2,000.00	1997	Remaining Life	-24.44	
20437	ET TERMINAL UNITS	Install Year	1977	Replacement Year \$20,000.00	1996	Remaining Life	-24.74	
FCU0047	NELSON, FAN COIL UNIT	Install Year	1977	Replacement Year \$2,000.00	1997	Remaining Life	-24.43	
FCU0049	Service Life 20.00 NELSON, FAN COIL UNIT	Install Year	1977	Replacement Year \$2,000.00	1996	Remaining Life	-24.74	
	Service Life 20.00	Install Year	1977	Replacement Year	1996	Remaining Life	-24.74	
				t Group Remaining Life ier 2 - Remaining Life		-24.51 -13.32		
				Tier 1 - Remaining Lie	fe	-14.72		
09083	Plumbing	\$139,00	00.00	5				
00000								
09091	Plumbing Point-of-Use		26,000.0	00				
09091 09127	Plumbing Point-of-Use Plumbing Fixtures	\$2			\$26,000.0	0		
09091	Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F	\$2 POINT OF U	8,000.0	\$26,000.00	·			
09091 09127	Plumbing Point-of-Use Plumbing Fixtures	\$2	2 6,000.(1977	\$26,000.00 Replacement Year	\$26,000.0 2002	Remaining Life	-19.43	
09091 09127	Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F	\$2 POINT OF U	2 6,000.0 1977 Asse	\$26,000.00 Replacement Year t Group Remaining Life	·	Remaining Life -19.43	-19.43	
09091 09127 20438	Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00	\$2 POINT OF U: Install Year	2 6,000.(1977 Asse T	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	·	Remaining Life	-19.43	
09091 09127	Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F	\$2 POINT OF U: Install Year	2 6,000.0 1977 Asse	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	2002	Remaining Life -19.43 -19.43	-19.43	
09091 09127 20438 09092	Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation	\$2 POINT OF U: Install Year \$	2 6,000.(1977 Asse T	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	·	Remaining Life -19.43 -19.43	-19.43	
09091 09127 20438 09092 09128	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D 	\$2 POINT OF U: Install Year \$	26,000.0 1977 Asse T 53,000.0	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year	2002	Remaining Life -19.43 -19.43 0 Remaining Life	-19.43 -1.41	
09091 09127 20438 09092 09128	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D 	\$2 POINT OF U: Install Year \$ OOMESTIC W	26,000.0 1977 Asse T 53,000.0 2005 Asse	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life	2002 \$3,000.00	Remaining Life -19.43 -19.43 0 Remaining Life -1.41		
09091 09127 20438 09092 09128 20439	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 	\$2 POINT OF U: Install Year \$ OMESTIC W Install Year	26,000.0 1977 Asse T 3,000.0 2005 Asse T	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	2002 \$3,000.00	Remaining Life -19.43 -19.43 0 Remaining Life		
09091 09127 20438 09092 09128 20439 09093	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping 	\$2 POINT OF U: Install Year \$ OMESTIC W Install Year	26,000.0 1977 Asse T 53,000.0 2005 Asse	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	2002 \$3,000.0 2020	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41		
09091 09127 20438 09092 09128 20439	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 	S2 POINT OF U: Install Year SOMESTIC W Install Year S9	26,000.0 1977 Asse T 3,000.0 2005 Asse T	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	2002 \$3,000.00	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41		
09091 09127 20438 09092 09128 20439 09093 09132	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping Domestic Water Piping 	S2 POINT OF U: Install Year SOMESTIC W Install Year S9	26,000.0 1977 Asse T 53,000.0 2005 Asse T 5,000.0 1977	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$54,000.00 Replacement Year	2002 \$3,000.0 2020	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41 0 Remaining Life		
09091 09127 20438 09092 09128 20439 09093 09132	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping Domestic Water Piping ET DOMESTIC WATER PIP 	SPOINT OF U: Install Year SOMESTIC W Install Year SS ING SYSTEM	26,000.0 1977 Asse T 53,000.0 2005 Asse T 5,000.0 1977	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$54,000.00	2002 \$3,000.00 2020 \$54,000.00	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41 0 Remaining Life -14.43	-1.41	
09091 09127 20438 09092 09128 20439 09093 09132 20440	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping Domestic Water Piping ET DOMESTIC WATER PIP Service Life 30.00 	SPOINT OF U: Install Year SOMESTIC W Install Year SS ING SYSTEM	26,000.0 1977 Asse T 53,000.0 2005 Asse T 5,000.0 1977	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$54,000.00 Replacement Year	2002 \$3,000.00 2020 \$54,000.00 2007	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41 0 Remaining Life -14.43	-1.41	
09091 09127 20438 09092 09128 20439 09093 09132 20440 09134	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping Domestic Water Piping ET DOMESTIC WATER PIP Service Life 30.00 DWV Piping ET DWV PIPING SYSTEM 	SPOINT OF U: Install Year SOMESTIC W Install Year SS ING SYSTEM	2005 Asse 7 3,000.0 2005 Asse 7 5,000.0 1977 Asse 1977 Asse	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 3 ,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 5 4,000.00 Replacement Year t Group Remaining Life \$41,000.00 Replacement Year t Group Remaining Life	2002 \$3,000.00 2020 \$54,000.00 2007	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41 0 Remaining Life -14.43 0 Remaining Life -14.43	-1.41	
09091 09127 20438 09092 09128 20439 09093 09132 20440 09134	 Plumbing Point-of-Use Plumbing Fixtures ET PLUMBING FIXTURES F Service Life 25.00 Hot Water Generation Hot Water Heater ET HOT WATER HEATER D Service Life 15.00 Plumbing Piping Domestic Water Piping ET DOMESTIC WATER PIP Service Life 30.00 DWV Piping ET DWV PIPING SYSTEM 	SPOINT OF US Install Year SOMESTIC W Install Year SPOMESTIC W Install Year ING SYSTEM Install Year	2005 Asse 7 3,000.0 2005 Asse 7 5,000.0 1977 Asse 1977 Asse	\$26,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life 00 \$3,000.00 Replacement Year t Group Remaining Life 00 \$54,000.00 Replacement Year t Group Remaining Life \$41,000.00 Replacement Year t Group Remaining Life ier 2 - Remaining Life	2002 \$3,000.00 2020 \$54,000.00 2007 \$41,000.00	Remaining Life -19.43 -19.43 0 Remaining Life -1.41 -1.41 0 Remaining Life -14.43 0 Remaining Life	-1.41 -14.43	

			#0 500 00				
DF0022	SUNROC WALL HUNG HIGH - LO		\$2,500.00	1001	D	00.74	
DF0023	Service Life 15.00 Install SUNROC WALL HUNG HIGH - LO	NDRI	Replacement Year \$2,500.00	1991	Remaining Life	-29.74	
ETDF001	Service Life 15.00 Install ELKAY BI-LEVEL BOTTLE FILLER	Year 1977	Replacement Year \$2,500.00	1991	Remaining Life	-29.74	
DF0021	Service Life 15.00 Install ELKAY WALL HUNG DRINKING FC		Replacement Year \$2,500.00	2018	Remaining Life	-2.72	
DF0024	Service Life 15.00 Install SUNROC WALL HUNG DRINKING		Replacement Year \$2,500.00	1991	Remaining Life	-29.74	
ETDF002	Service Life 15.00 Install ELKAY BI-LEVEL NO FILTERS		Replacement Year \$2,500.00	2018	Remaining Life	-2.72	
	Service Life 15.00 Install		Replacement Year	2018	Remaining Life -16.23	-2.72	
			t Group Remaining Life ier 2 - Remaining Life		-16.23		
		I	Tier 1 - Remaining Life	l ife	-15.28		
09084	Electrical \$	597,630.00		Life	10.20		
09095	Primary Service	\$180,400.	00				
09141	Transformers	<i><i><i>q</i></i> 100,1001</i>		\$80,400.0	0		
23428	CUTLER HAMMER TRANSFORME	ER - C	\$15,400.00	,,	-		
23408	Service Life 40.00 Install ` ITE TRANSFORMER	Year 1977	Replacement Year \$37,000.00	2016	Remaining Life	-4.74	
23426	Service Life 40.00 Install ITE TRANSFORMER	Year 1977	Replacement Year \$28,000.00	2016	Remaining Life	-4.74	
	Service Life 40.00 Install		Replacement Year t Group Remaining Life	2016	Remaining Life -4.74	-4.74	
09143	MDP (Main Distributior	7330		\$100,000.0			
20311	ET - MDP - 277/480V, 2000A, 3PH,	4WIF	\$100,000.00	<i> </i>	-		
	Service Life 40.00 Install	Year 1979	Replacement Year	2018	Remaining Life	-2.74	
			t Group Remaining Life		-2.74		
			ier 2 - Remaining Life		-3.63		
09096	Building Electrical Dist	\$417,230.	00	¢074 400 0			
09146 20313	Electical Wiring ET - BUILDING ELECTRICAL DIST	סופו ו	\$374,430.00	\$374,430.0	0		
20313	Service Life 40.00 Install		Replacement Year	2018	Remaining Life	-2.74	
			t Group Remaining Life		-2.74	2.17	
09148	Electrical Panels			\$42,800.0			
23430	CUTLER HAMMER PANEL		\$4,000.00				
EP0023	Service Life 40.00 Install LOAD CENTER PANEL BOARD J	Year 1977	Replacement Year \$3,400.00	2016	Remaining Life	-4.74	
EP0029	Service Life 40.00 Install LOAD CENTER PANEL BOARD H		Replacement Year \$5,600.00	2014	Remaining Life	-6.74	
EP0025	Service Life 40.00 Install LOAD CENTER PANEL BOARD W	Year 1979	Replacement Year \$6,200.00	2018	Remaining Life	-2.74	
EP0022	Service Life 40.00 Install LOAD CENTER PANEL BOARD V	Year 1979	Replacement Year \$6,200.00	2018	Remaining Life	-2.74	
EP0021	Service Life 40.00 Install LOAD CENTER PANEL BOARD EN		Replacement Year \$6,200.00	2018	Remaining Life	-2.74	
	Service Life 40.00 Install		Replacement Year	2018	Remaining Life	-2.74	

EP0024	LOAD CENTER PANEL BO	DARD H		\$6,200.00				
EP0030	Service Life 40.00 LOAD CENTER PANEL BO	Install Year DARD AA	1979	Replacement Year \$5,000.00	2018	Remaining Life	-2.74	
	Service Life 40.00	Install Year		Replacement Year t Group Remaining Life	2018	Remaining Life -3.24	-2.74	
				Tier 2 - Remaining Life		-2.79		
			-	Tier 1 - Remaining L	.ife	-3.04		
09085	Building Interior	\$2,668,3	07.00					
09098	Ceiling Systems	\$	50,206.	00				
09153	Ceilings				\$50,206.	00		
20139	CEILINGS, DROP-IN, 1997			\$5,634.00				
20153	Service Life 30.00 CEILINGS, SKYLIGHT, 19			Replacement Year \$26,100.00	2020	Remaining Life	-0.73	
20149	Service Life 30.00 CEILINGS, HARDLID, 197	Install Year 7		Replacement Year \$18,472.00	2006	Remaining Life	-14.74	
	Service Life 30.00	Install Year		Replacement Year	2006	Remaining Life	-14.74	
				et Group Remaining Life Tier 2 - Remaining Life		-13.17 -13.17		
09099	Interior Openings	\$	ا 60,175.			-13.17		
09154	Hollow Metal Frame	Ŷ			\$3,675.	00		
22357	ET INTERIOR HOLLOW M	ETAL FRAME		\$3,675.00	, - ,			
	Service Life 17.00	Install Year		Replacement Year t Group Remaining Life	1993	Remaining Life -27.74	-27.74	
09156	Storefront		, 1000		\$37,500.			
22358	ET INTERIOR STOREFRO	NT WALLS		\$37,500.00				
	Service Life 17.00	Install Year	1977 Asse	Replacement Year t Group Remaining Life	1993	Remaining Life -27.74	-27.74	
09157	Doors				\$19,000.	00		
22359	ET ROLLUP DOOR			\$15,000.00				
22360	Service Life -3.00 ET INTERIOR STOREFRO		1977	Replacement Year \$4,000.00	1974	Remaining Life	-47.74	
	Service Life 17.00	Install Year		Replacement Year	1993	Remaining Life	-27.74	
				et Group Remaining Life		-43.53 -32.72		
09100	Flooring Systems	\$1	ا .58,040	īer 2 - Remaining Life 00		-JZ.1Z		
09158	Floors	ΨI		~~	\$158,040.	00		
20171	FLOORS, CARPET, 2014			\$8,631.00				
20158	Service Life 10.00 FLOORS, CARPET, 1987	Install Year	1977	Replacement Year \$4,362.00	1986	Remaining Life	-34.74	
20179	Service Life 35.00 FLOORS, VCT, 2004	Install Year	1977	Replacement Year \$21,490.00	2011	Remaining Life	-9.74	
20166	Service Life 30.00 FLOORS, CARPET, 2001	Install Year	1977	Replacement Year \$6,978.00	2006	Remaining Life	-14.74	
20175	Service Life 25.00 FLOORS, VCT, 1977	Install Year	1977	Replacement Year \$48,524.00	2001	Remaining Life	-19.74	
20163	Service Life 40.00 FLOORS, CARPET, 1992	Install Year	1977	Replacement Year \$6,120.00	2016	Remaining Life	-4.74	
	Service Life 36.00	Install Year	1977	Replacement Year	2012	Remaining Life	-8.74	

20193	FLOORS, BRICK, 1977			\$53,235.00				
20169	Service Life 40.00 FLOORS, CARPET, 2004	Install Year	1977	Replacement Year \$3,735.00	2016	Remaining Life	-4.74	
20159	Service Life 20.00 FLOORS, CARPET, 1991	Install Year	1977	Replacement Year \$2,817.00	1996	Remaining Life	-24.74	
20155	Service Life 35.00 FLOORS, CARPET, 1985	Install Year	1977	Replacement Year \$2,148.00	2011	Remaining Life	-9.74	
	Service Life 37.00	Install Year		Replacement Year t Group Remaining Life	2013	Remaining Life -9.29 -9.29	-7.74	
09101	Walls	¢7.7/	ا 40,000.0	ier 2 - Remaining Life		-9.29		
09159	Wall Surface	φ2,24	10,000.0		\$2,240,000.0	0		
22070	ET WALL SURFACE		¢'	2,240,000.00	<i>\$</i> 2,240,000.0	<i>1</i> 0		
22010	Service Life 12.00	Install Year	1977	Replacement Year	1988	Remaining Life	-32.74	
		motali real		t Group Remaining Life	1000	-32.74	02.11	
				ier 2 - Remaining Life		-32.74		
09102	Attached Furnishings	\$8	35,000.0					
09161	Millwork				\$85,000.0	00		
20215	MILLWORK, 1977			\$85,000.00				
	Service Life 42.00	Install Year	1977	Replacement Year	2018	Remaining Life	-2.74	
				t Group Remaining Life		-2.74		
09103	Signago	¢-	ا 74,886.0	ier 2 - Remaining Life		-2.74		
09103	Signage Interior Signage	ቅ፤	4,000.0	10	\$74,886.0	0		
22072	ET BUILDING SIGNAGE			\$74,886.00	φ <i>1</i> 4 ,000.0	<i>1</i> 0		
22012	Service Life 15.00	Install Year	1977	Replacement Year	1991	Remaining Life	-29.74	
		motali real		t Group Remaining Life		-29.74		
				ier 2 - Remaining Life		-29.74		
				Tier 1 - Remaining L	ife	-29.94		
9086	Building Structure	\$355,70	00.00					
09105				10				
	Envelope	\$35	55,700.0	10				
09164	Exterior Doors				\$165,000.0	00		
09164 21636	Exterior Doors EXTERIOR STOREFRONT	DOORS 197	·	\$54,000.00	·			
	Exterior Doors	DOORS 197 Install Year	1977		\$165,000.0 2011	00 Remaining Life	-9.74	
21636 21638	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00	DOORS 197 Install Year AL DOORS 1 Install Year	1977	\$54,000.00 Replacement Year \$36,000.00 Replacement Year	·		-9.74 -2.74	
21636	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOO	DOORS 197 Install Year AL DOORS 1 Install Year	1977 1977	\$54,000.00 Replacement Year \$36,000.00	2011 2018	Remaining Life		
21636 21638	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00	DOORS 197 Install Year AL DOORS 1 Install Year	1977 1977 1977	\$54,000.00 Replacement Year \$36,000.00 Replacement Year	2011	Remaining Life		
21636 21638	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOO	DOORS 197 Install Year AL DOORS 1 Install Year RS 1977	1977 1977 1977	\$54,000.00 Replacement Year \$36,000.00 Replacement Year \$75,000.00 Replacement Year	2011 2018	Remaining Life Remaining Life Remaining Life -10.48	-2.74	
21636 21638 21640	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOOI Service Life 30.00 Glazing/Openings EXTERIOR WINDOWS 197	DOORS 197 Install Year AL DOORS 1 Install Year RS 1977 Install Year	1977 1977 1977 Asset	\$54,000.00 Replacement Year \$36,000.00 Replacement Year \$75,000.00 Replacement Year	2011 2018 2006	Remaining Life Remaining Life Remaining Life -10.48	-2.74 -14.74	
21636 21638 21640 09166	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOOI Service Life 30.00 Glazing/Openings EXTERIOR WINDOWS 197 Service Life 38.00 EXTERIOR STOREFRONT	DOORS 197 Install Year AL DOORS 1! Install Year RS 1977 Install Year 77 Install Year	1977 1977 1977 Asset	\$54,000.00 Replacement Year \$36,000.00 Replacement Year \$75,000.00 Replacement Year t Group Remaining Life	2011 2018 2006	Remaining Life Remaining Life Remaining Life -10.48	-2.74	
21636 21638 21640 09166 21643	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOOL Service Life 30.00 Glazing/Openings EXTERIOR WINDOWS 197 Service Life 38.00	DOORS 197 Install Year AL DOORS 1! Install Year RS 1977 Install Year 77 Install Year	1977 1977 1977 Asset 1977 1977	\$54,000.00 Replacement Year \$36,000.00 Replacement Year \$75,000.00 Replacement Year t Group Remaining Life \$183,000.00 Replacement Year \$7,700.00 Replacement Year	2011 2018 2006 \$190,700.0	Remaining Life Remaining Life Remaining Life -10.48 00	-2.74 -14.74	
21636 21638 21640 09166 21643	Exterior Doors EXTERIOR STOREFRONT Service Life 35.00 EXTERIOR HOLLOW MET Service Life 42.00 EXTERIOR ROLLUP DOOI Service Life 30.00 Glazing/Openings EXTERIOR WINDOWS 197 Service Life 38.00 EXTERIOR STOREFRONT	DOORS 197 Install Year AL DOORS 1! Install Year RS 1977 Install Year 77 Install Year 1977	1977 1977 1977 Asset 1977 1977 Asset	\$54,000.00 Replacement Year \$36,000.00 Replacement Year \$75,000.00 Replacement Year t Group Remaining Life \$183,000.00 Replacement Year \$7,700.00	2011 2018 2006 \$190,700.0 2014	Remaining Life Remaining Life Remaining Life -10.48 00 Remaining Life Remaining Life	-2.74 -14.74 -6.74	

					\$157,0	00.00		
23446	DOVER HYDRAULIC	PASSENGER ELE		\$120,000.00				
	Service Life 25.00	Install Year	1977	Replacement	Year 2001	Remaining Life	-19.74	
23427	XFMR TP1			\$37,000.00				
	Service Life 40.00	Install Year	1977	Replacement			-4.74	
				t Group Remaining		-16.20		
			Т	ïer 2 - Remaining I	Life	-16.20		
				Tier 1 - Rema	iining Life	-16.20		
	Replacem	ent Cost	\$	5,185,495.00	Expected Life	23.03	Effective Building Age	43.86
BLDG SQFT	74,886.00	Replacement Cos	st/SQF	T \$69.25		Building Def	erred Maintenance	\$5,185,495.00
	Average Bu	uilding Remaining L	ife	-20.84				

Total Deferred Maintenance \$5,185,495.00